



**NB - ALL DPCs & MEMBRANES INTERRUPTING MASONRY BED JOINTS ARE REQUIRED TO BE BEDDED ABOVE AND BELOW WITH MORTAR**

TIMBER FRAME CONSTRUCTION  
MINIMUM 150mm ABOVE EXTERNAL  
GROUND LEVEL

**JUTA GP<sup>®</sup> TAPE**  
DOUBLE SIDED TAPE BELOW  
SOLE PLATE FIXING

**300TT PROTECTION FLEECE**  
TO BE USED WHERE NO  
INSULATION USED AS PROTECTION

STANDARD CAVITY TRAY  
SEALED TO GAS MEMBRANE  
USING JUTA GP<sup>®</sup> TAPE.

**JUTA GP<sup>®</sup> RADON DPC**

**JUTA GP<sub>2</sub><sup>®</sup> HIGH PERFORMANCE DPM**  
APPLIED ONTO MIN. 40mm SAND BLINDING

**JUTA GP<sup>®</sup> TAPE**  
TAPED JOINT OR HEAT  
WELDED SEAM JOINT

100mm

CLIENT	JUTA UK LTD
PROJECT	GP <sup>®</sup> 2 Standard Details



- NOTES**
- Detail is generic to application so should be used as a guide not a specific installation detail.
  - GP<sup>®</sup> 2 is a proprietary radon resistant DPM, manufactured and certified to adhere to the requirements of BRE 211: 2015 as a radon barrier.
  - GP<sup>®</sup> 2 provides radon protection, in accordance with Approved Doc C (UK) and Technical Guidance Document C (Ireland).
  - Jointing and sealing using tapes is acceptable where anticipated design service life does not exceed 25 years.
  - Jointing and sealing by hot air welding is recommended where the anticipated design service life is required to exceed 60 years.
  - The use of butyl and bitumen based tapes in environments where VOC and Hydrocarbons are a perceived risk should be avoided. A thermal/welded joint system should be adopted.
  - It should be noted that the suitability of the welded joint is defined by the joint integrity, as tested in accordance with CIRIA C735: 2014. This is most commonly tested by air lance integrity testing to ASTM D4437-08: 2013. If the joint passes this test it is deemed acceptable in the verification process.
  - In all cases it is recommended the installation of gas barrier geomembranes is completed by a suitably qualified and accredited installer (NVQ L2/TWI/CSWIP or equivalent). Juta UK can offer advice as to the suitable/recommended installers.
  - All design decisions made by others that might have an impact on the gas and waterproof design performance should be brought to the attention of the design team and Juta UK Ltd. Final decisions and/or any recommendations should be approved by the design team and Juta UK Ltd.
  - Dimensions are not to be scaled from this drawing. All written measurements are to be checked on site by the contractor.
  - All rights described in chapter IV of the copyright, design and patents act 1988 have been generally asserted.

DRAWING TITLE			
<b>JUTA GP<sup>®</sup>2 DPM</b>			
TIMBER FRAME CONSTRUCTION - PERIMETER DETAIL.			
DRAWING NUMBER			
JUTA.GP2.030			

DRAWN BY	CHECKED BY	SCALE	DATE
PD	PF	Not to Scale	Sep. 2020



MELTON GROVE WORKS  
BLACKPOOL ROAD  
LYTHAM  
FY8 5PL  
Tel: 01772 754177