

**NB- All DPC's & membranes interrupting masonry bed joints are required to be bedded above and below with mortar.**

**JUTA GP® 1 GAS RESISTANT DPM**  
Applied on top of block and beam floor prior to finishes.

**STANDARD CAVITY TRAY**  
sealed to gas DPC using JUTA Tape

**JUTA GP® TELESCOPIC VENT**  
To provide minimum 6000mm<sup>2</sup> venting performance. Centres defined by site specific design. See product datasheet for more details.

**CLEAR VOID**  
min height 150mm

**JUTA GP® DPC**  
Juta GP1 can be used as the DPC providing there is no lateral shear as per BS8215:1991. If lateral shear is a design consideration then Juta GP DPC to be used

**JUTA GP® TAPE**  
Taped joint or heat welded seam joint

**BLOCK AND BEAM FLOOR**

